


Air density ( $\gamma$ ): 1.20 kg/m<sup>3</sup>

Installation type "B": free inlet, ducted outlet

12000 m<sup>3</sup>/h fan test chamber according to AMCA 210/05 fig. 12

Free field Lp(A) measurements at 1 m according to ISO 3746:2011

<b>Unit type:</b>	CBT 80VT XPL	<b>Motor code:</b>	-	<b>Motor T.H.:</b>	NO
<b>Test nr.:</b>	2309	<b>Motor power [W]:</b>	3000	<b>Capacitor [<math>\mu</math>F]:</b>	-
<b>Date:</b>	2017/04/21	<b>Motor poles:</b>	4	<b>Unit max. abs. current [A]:</b>	7,1/12,3
<b>Power supply [V]:</b>	400/230 3~	<b>Mot. prot. class:</b>	IP55	<b>Unit max. abs. power [W]:</b>	3780
<b>Frequency [Hz]:</b>	50	<b>Mot. ins. class:</b>	F		



Data are not certified by AMCA