


Unit type: CBT 6000VT X18  
 Test nr.: 2641  
 Date: 2017/10/24  
 Power supply[V]: 400/230 3~  
 Frequency [Hz]: 50

Motor code: MTR.B3.1,5  
 Motor power [W]: 1500  
 Motor poles: 4  
 Mot. prot. class: IP55  
 Mot. ins. class: F

Motor T.H.: NO  
 Capacitor [ $\mu$ F]: -  
 Unit max. abs. current [A]: 3,2/5,5  
 Unit max. abs. power [W]: 1640

ErP status: ErP 2018



Data are not certified by AMCA