


| | | | | | |
|-------------------------|------------|--------------------------|---------|---------------------------------------|--------|
| Unit type: | VDI 5045 W | Motor code: | 201101N | Motor T.H.: | YES IN |
| Test nr.: | 2877 | Motor power [W]: | 1100 | Capacitor [μF]: | 32 |
| Date: | 2018/05/04 | Motor poles: | 4 | Unit max. abs. current [A]: | 6,4 |
| Power supply[V]: | 230 1~ | Mot. prot. class: | IP55 | Unit max. abs. power [W]: | 1370 |
| Frequency [Hz]: | 50 | Mot. ins. class: | F | | |

ErP status: Not subjected to Erp Regulation



Data are not certified by AMCA