


Air density (γ): 1.20 kg/m³
 Installation type "B": free inlet, ducted outlet
 12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Fan type:	DAIN 10/10 XPL	Motor code:	MTR.4P.550.3V	Motor T.H.:	YES IN
Test nr.:	562, 568, 569	Motor power [W]:	550	Capacitor [μF]:	16
Date:	2014/10/28	Motor poles:	4	Fan max. abs. current [A]:	5.5
Power supply[V]:	230 1~	Mot. prot. class:	IP44		
Frequency [Hz]:	50	Mot. ins. class:	F		

Fan ErP status: ErP 2015



Data are not certified by AMCA