


Air density (γ): 1.20 kg/m³
Installation type "B": free inlet, ducted outlet
12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Fan type:	DAIN 7/7 XPL	Motor code:	MTR.4P.147.1V.IP55	Motor T.H.:	YES IN
Test nr.:	864	Motor power [W]:	147	Capacitor [μF]:	6.3
Date:	2015/03/06	Motor poles:	4	Fan max. abs. current [A]:	1.3
Power supply[V]:	230 1~	Mot. prot. class:	IP55		
Frequency [Hz]:	50	Mot. ins. class:	F		

Fan ErP status: not subjected to ErP Regulation (Pin<280 W)



Data are not certified by AMCA