

CMC VENTILAZIONE

Air density (γ): 1.20 kg/m³
Installation type "B": free inlet, ducted outlet
12000 m³/h test chamber
Fan test laboratory according to AMCA 210/99 fig. 12

Fan type: DAIN 9/7
Motor type: ~~MTR.4P.420.3V.F~~ *201100M*
Test nr.: 690, 693, 697
Date: 2014/06/25
Erp status: ErP 2015

Motor power [W]: 420
Power supply[V]: 230 1~
Frequency[Hz]: 50
Capacitor [μ F]: 12.5

Max. current [A]: 4
Prot. class: ~~IP44~~ *IP20*
Ins. class: F
T.H.: YES-IN

