


Air density (γ): 1.20 kg/m³
 Installation type "B": free inlet, ducted outlet
 12000 m³/h fan test chamber according to AMCA 210/05 fig. 12
 Free-field inlet side Lp(A) measurements at 1 m according to ISO 3746:2011

Fan type: DAIN 9/9 XPL
 Test nr.: 2581 - 2584
 Date: 2017/09/20
 Power supply[V]: 230 1~
 Frequency [Hz]: 50

Motor code: 2011017
 Motor power [W]: 420
 Motor poles: 4
 Mot. prot. class: IP55
 Mot. ins. class: F

Motor T.H.: YES IN
 Capacitor [μ F]: 8
 Fan max. abs. current [A]: 3,8

Fan ErP status: ErP 2015



Data are not certified by AMCA