


Air density (γ): 1.20 kg/m³
 Installation type "B": free inlet, ducted outlet
 12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Fan type:	DAIN 9/7 XPL	Motor code:	2011017	Motor T.H.:	YES IN
Test nr.:	2556 - 2559	Motor power [W]:	420	Capacitor [μF]:	8
Date:	2017/09/08	Motor poles:	4	Fan max. abs. current [A]:	4
Power supply[V]:	230 1~	Mot. prot. class:	IP55		
Frequency [Hz]:	50	Mot. ins. class:	F		

Fan ErP status: ErP 2015



Data are not certified by AMCA