


Air density (γ): 1.20 kg/m³
 Installation type "A": free inlet, free outlet
 12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Fan type:	DARE 133/150 XPL	Motor code:	2111000	Motor T.H.:	YES IN
Test nr.:	640, 643, 644	Motor power [W]:	60	Capacitor [μF]:	4
Date:	2014/05/23	Motor poles:	2	Fan max. abs. current [A]:	0.84
Power supply[V]:	230 1~	Mot. prot. class:	IP 44		
Frequency [Hz]:	50	Mot. ins. class:	F		

Fan ErP status: Not subjected to ErP Regulation (Pe<125 W)



Data are not certified by AMCA