


Air density (γ): 1.20 kg/m³

Installation type "A": free inlet, free outlet

12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Fan type:	RFB 190/45 XPL	Motor code:	SM00064	Motor T.H.:	SW alarm
Test nr.:	20, 21, 22, 23	Motor power [W]:	107 (Win)	Capacitor [μF]:	-
Date:	2013/03/05	Motor poles:	-	Fan max. abs. current [A]:	0.7
Power supply[V]:	230 1~	Mot. prot. class:	IP 54		
Frequency [Hz]:	50	Mot. ins. class:	F		

Fan ErP status: Not subjected to ErP Regulation (Pe<125 W)



Data are not certified by AMCA