


<b>Fan type:</b>	VDI 6000 PRO	<b>Motor code:</b>	201101T	<b>Motor T.H.:</b>	YES OUT
<b>Test nr.:</b>	3076	<b>Motor power [W]:</b>	750	<b>Capacitor [<math>\mu</math>F]:</b>	-
<b>Date:</b>	2018/11/15	<b>Motor poles:</b>	4	<b>Fan max. abs. current [A]:</b>	2,6/1,5
<b>Power supply[V]:</b>	230/400 3~	<b>Mot. prot. class:</b>	IP54	<b>Fan max. abs. power [W]:</b>	585
<b>Frequency [Hz]:</b>	50	<b>Mot. ins. class:</b>	F		

ErP status: Not subjected to Erp Regulation



Data are not certified by AMCA